

## FIELD INSPECTION REPORT

<b>Project Name:</b>	Mountain Valley Pipeline	<b>Inspector:</b>	Marshall Willis
<b>Inspection Date:</b>	Friday, July 9, 2021	<b>Project Contact:</b>	Brian Clauto, Cory Chalmers
<b>Spread G: Montgomery County</b>	STA 11762+50 – 11770+00 STA 12001+72 – 12008+53 MVP-MN-266/266.03/268 MVP-MLV-AR-26	<b>Weather:</b>	Rainy

**ACTIVE STAGE OF CONSTRUCTION:** (Check all that apply)

- Tree Felling     
  Clearing/Grubbing     
  Grading     
  Trenching     
  Stringing/Welding  
 Lowering/Backfilling     
  Final Restoration     
  Temp. Stabilization     
  Perm. Stabilization     
 Dormant

- |                                                                                                                                                                                    | Yes                                 | No                                  | N/A                      |
|------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------|-------------------------------------|--------------------------|
| 1. Are controls installed and implemented in accordance with the approved erosion and sediment control plan and stormwater management plans?                                       | <input checked="" type="checkbox"/> | <input type="checkbox"/>            | <input type="checkbox"/> |
| 2. Are all control measures properly maintained in effective operating condition in accordance with good engineering practices and, where applicable, manufacturer specifications? | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |
| 3. Areas of offsite sediment deposition observed?                                                                                                                                  | <input type="checkbox"/>            | <input checked="" type="checkbox"/> | <input type="checkbox"/> |

Comments: Inspected the following resources: S-IJ52, W-IJ46-PEM and S-G36.

**Routine Maintenance:** (72-Hour Deadline from Notification)

- MVP-MN-266.03: Discharge bypassing P1 and causing minor erosion.

**Ineffective Controls:** (24-Hour Deadline from Notification)

- STA 12004+00: P1 repair needed.
- MVP-MN-266.03: P1 undermined.

**Recommended Corrective Action:** Maintain and install all controls per the approved PSS&S.

**Deadline:** Various - See Comments

The recommended corrective action deadline date applies to all conditions noted on this report unless otherwise noted. If listed condition(s) currently constitute non-compliance and/or corrective actions are not completed by the deadline, other enforcement actions may be issued to the entity responsible for ensuring compliance on the above project.

**Inspector Signature:** Marshall Willis

**Date:** Friday, July 9, 2021

## FIELD INSPECTION PHOTO LOG

**Project Name:** Mountain Valley Pipeline

**Date:** Friday, July 9, 2021

**Figure 1: MVP-MN-266.03** – Discharge bypassing P1 causing minor erosion.

BRG: 72°E (T) LAT: 37.288341 LON: -80.328702 ±98ft ALT: 2290ft



**Figure 2: MVP-MN-266.03** – P1 undermined.

BRG: 130°SE (T) LAT: 37.287147 LON: -80.330054 ±32ft ALT: 2041ft



**Figure 3: STA 12004+00** – P1 repair needed.

BRG: 301°NW (T) LAT: 37.268880 LON: -80.315470 ±16ft ALT: 1604ft



**Figure 4: STA 11976+00** – Controls in place and functioning properly.

BRG: 344°N (T) LAT: 37.269784 LON: -80.323098 ±16ft ALT: 1709ft

