

FIELD INSPECTION

Project Name:	Mountain Valley Pipeline	Inspector:	Matthew Grant
Inspection Date:	Thursday, March 28, 2019	Project Contact:	Brian Clauto
Spread: Montgomery County MP225-226 St11932-11979 Giles County MP216-217 St11471-11435 MP212-211 St11227-11163	Spread G	Weather (Wet/Dry/Rain):	Dry
STAGE OF CONSTRUCTION: (Check all that apply)			
Clearing	Rough Grading	Trench Excavation	Pipe Assembly, Testing & Installation
Backfilling and Grade	e Restoration	& Stabilization	Other: Dormant
		Yes No N/A	
Are controls installed and implemented in accordance with the approved □□□ crosion and sediment control plan and stormwater management plans?			
Are all control measures properly maintained in effective operating condition in accordance with good engineering practices and, where applicable, manufacturer specifications?			
3 Areas of offsite sediment deposition were observed? □ □ □			
Comments: ECD's and stabilization are functioning between St#11932+54 and 11961+00 St#11191+00 hole in bridge wattle St#11163+30 hole in P1 fence			
Recommended Corrective Action: Maintain controls per the approved plans and annual standard and specs.			
Deadline: _Within 24hr notification The recommended corrective action deadline date applies to all conditions noted on this report unless otherwise noted. If listed condition(s) currently constitute non-compliance and/or corrective actions are not completed by the deadline, other enforcement actions may be issued to the entity responsible for ensuring compliance on the above project. Inspector Signature:			



FIELD INSPECTION PHOTO LOG

Project Name: Mountain Valley Pipeline Date:Thursday, March 28, 2019



Fig. 2 St#11163+30 hole in P1 fence



 Fig. 3 Near streams S-0012 ECD's are in place and functioningSt

